

LOCKOUT TAGOUT TYPES

What Would Cosmo Do?



Cosmo knows when to use lockout tagout

Exclusive Control vs. Single Isolation vs. Complex **Exclusive Control**

Work on Cord-and Plug-connected electric equipment for which the hazards of unexpected energies are controlled by the unplugging of equipment from the energy source



The plug is under exclusive control of employee performing maintenance



Exclusive Control does not require utilization of isolation procedures

Single Isolation

Equipment has a single energy source that can be readily identified and isolated

Employees are not required to utilize an energy source procedure when equipment has no potential for stored energy after shutting down

Complex

Entails multiple energy sources, crews, and locations. Requires an equipment-specific plan to aid in the execution and define a person in charge.

Plans shall identify and account for all persons who might be exposed to hazards. Prior to engaging in services, individuals planning to perform work must determine and implement all necessary lockout procedures before work is performed

The Lockout/Tagout Standard covers around 3 million workers

<https://www.EHStoday.com/archive/article/21903835/lockout-tagout-a-matter-of-control>

29 CFR 1910.147



***Safety Is Everyone's
Responsibility***

BYU

Risk Management and Safety

RMB | 801-422-4468